



# BIG FPRO

**PERFORMANCE  
DATA SHEET**



**WaterMark**  
AS/NZS 3497  
Licence No. WM-022909

# PERFORMANCE DATA SHEET

## MANUFACTURER

**Name:** ATLAS FILTRI SRL  
**Address:** Via Pierobon 32 - Limena, 35010, PD  
**Phone:** +39 049769055

## SELLER

**Name:** Atlas FILTRI SRL distributors

## PRODUCTS

- *BIG F PRO 156*
- *BIG F PRO 256*
- *BIG F PRO 267*



## SUBSTANCES REDUCTION

The **Atlas Filtri** models listed above have been tested and certified under **AS/NZS 4020 and AS/NZS 3497 and relevant NSF Standard listed in Clause 1.2 for reduction of Sediment**. The performance of these products has been verified and substantiated as the test data summarized below indicates. These substances may not be in your water.

CLASS	TREATMENT TYPE	PLAIN LANGUAGE DESCRIPTION	CONFORMANCE TO NSF STANDARDS AND PROTOCOLS
IV	Turbidity and particulate removal	Reduce Cloudiness	NSF 42

SUBSTANCE	NHMRC ADWG or USEPA SDWA MCL	AVERAG INFLUENT CONCENTRATION	MAXIMUM EFFLUENT CONCENTRATION	MINIMUM PERCENT REMOVAL	AVERAGE EFFLUENT CONCENTRATION	AVERAGE PERCENT REMOVAL
Sediments	-	16638	515	> 98.01%	269	> 98.2%

**MCL** - Maximum Contaminant level  
**Mg/l** - milligrams per litre

### Testing conditions:

- Flow rate was controlled at 24 gpm
- pH 7,8 +/- 0,05
- Temperature 21 +/- 3 degree C

*Refer to your owner's guide for more specific product and warranty information and to avoid contamination from improper handling and installation. Performance will vary on local water conditions. The substances reduced by this product are not necessarily in your water.*

## USE GUIDELINE

- Minimum Operating pressure 50 kPa
- Maximum operating pressure 1205 kPa
- Do not Allow exposure to temperature below 4°C
- Maximum operating temperature 45°C
- Nominal Flow rate

MODEL	FLOW-RATE
DP BIG 156	54 L/min
DP BIG 256	70 L/min
DP BIG 267	95 L/min

- This system has to installed according to local plumbing codes on the cold water line
- Replacement cartridges

MODEL	CARTRIDGE
DP BIG 156	TS 10 BIG - CPP 10 BIG (CBEC 10 BIG)
DP BIG 256	TS 20 BIG - CPP 20 BIG (CBEC 20 BIG)
DP BIG 267	TS 20 BIG - CPP 20 BIG (CBEC 20 BIG)

- This system requires regular replacement of the filter cartridge to maintain proper operation. Varying Sediment or organic substances levels may affect replacement frequency.
- Be sure to change the filter cartridge at least every six months; Or whenever you detect a change in taste or odour or decrease in flow.



**CAUTION** - Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. This System may be used on disinfected water that may contain filterable cyst.

Date: 27/10/2020

*Manufacturer's Signature*



A handwritten signature in black ink, consisting of a series of loops and strokes.

We value  
what really  
matters.  
**Water**



IT'S MADE IN ITALY



ATLAS FILTRI S.r.l. | via Pierobon, 32 | 35010 Limena, Italy  
Tel. +39.049.76.90.55 | Fax +39.049.76.99.94 | [www.atlasfiltri.com](http://www.atlasfiltri.com)